



**EVERGREEN  
METROPOLITAN  
DISTRICT**

*Water & Wastewater  
30920 Stagecoach Blvd  
Evergreen, CO 80439  
(303) 674-4112 Fax (303) 674-7267*

**2022 WATER HAULING REGULATIONS**

**GENERAL**

The season for hauling will be year-round. Hauling may be done 24 hours per day if HAULER has a card to the system.

There will be a \$500 annual (non-refundable) permit fee. One card will be assigned per permit. A \$25 fee will be charged for each additional card. If additional cards are issued, the administrative office must know the license plate number of the truck the card will be assigned to. This is for inspection and tracking purposes. All accounts will be billed on a monthly basis. Cost per thousand gallons is \$30.00 (\$.03 per gallon), or fraction thereof. The equipment will do all the logging of water hauled, according to the card used. **New requirement for 2022:** If an account goes 30 days delinquent the card issued to the account will be deactivated and must be paid in full for card to be re-activated. Before your card will be activated for the 2022 year your account must be current with no overdue balance.

Damages to District property will be billed at cost plus 28% (18% on materials and 10% on labor), and could also include forfeiture of right to use water hauling station.

Water sales from the Bulk Station may be stopped or restricted due to environmental (drought) or other reasons deemed necessary by the Evergreen Metropolitan District.

Inoperability of the Bulk Station during off business hours (between 4:30 p.m. - 8:00 a.m. weekdays) or on weekends will not be construed as an emergency. The District will investigate and/or service problem with the station on the next business day.

**TRUCKS AND TANKS**

A visual inspection of every truck or tank used in hauling must be done on an annual basis by Evergreen Metropolitan District personnel.

**Trucks must have an air gap system approved by EMD personnel before hauling card will be activated.** All HAULERS MUST SUPPLY THEIR OWN HOSE. Hose must be capable of hooking up to a 2-1/2” fire hydrant thread. Hose must have 2-1/2” female thread. All HAULERS must fill at the top using an air gap. DO NOT BOTTOM FILL INTO TANK.

Description of material in non-potable tank must be put on Permit, with specific antidote or manufacturer’s name and telephone number. NO CHEMICAL MIXING SHALL BE DONE AT THE FILL STATION.

**PENALTIES FOR VIOLATIONS**

Any water HAULER violating the air gap filling regulation will lose all privileges of hauling from the Evergreen Metropolitan District water system. Hauling without a permit or from unauthorized areas, such as fire hydrants, will result in a \$150.00 fine and revocation of the HAULER’S permit. All costs incurred by such acts shall be billed to the HAULER, according to the fee schedule, including all legal costs, state fines, lawsuits and damages.

Violation of any of the aforementioned regulations will result in the immediate revocation of the water hauling permit. A hearing may be held, if requested by the HAULER in writing. Submit request for hearing to:

Dominique Devaney, Administrative and HR Manager  
Evergreen Metropolitan District  
30920 Stagecoach Blvd.  
Evergreen, CO 80439

**Permit fee will not be prorated and is in effect from January 1 through December 31 of the year issued.**

**I have read and understand these regulations.**

**Date** \_\_\_\_\_

\_\_\_\_\_  
**Printed Name**

\_\_\_\_\_  
**Signature**